


# SOURCE WATER ASSESSMENT

## FOR THE CITY OF BOWIE PRINCE GEORGES COUNTY, MD



Prepared By  
Water Management Administration  
Water Supply Program  
March 2005



*Robert L. Ehrlich, Jr.*  
Governor

*Kendl P. Philbrick*  
Secretary

*Michael S. Steele*  
Lt. Governor

*Jonas A. Jacobson*  
Deputy Secretary

# TABLE OF CONTENTS

|   | Page |
|---|------|
| Summary .....   | 1    |
| Introduction.....   | 2    |
| Well Information.....   | 2    |
| Table 1. City of Bowie Well Information   |      |
| Hydrogeology.....   | 2    |
| Source Water Assessment Area Delineation .....                                    | 3    |
| Table 2. Parameters used for the Source Water Assessment Area delineations        |      |
| Potential Sources of Contamination.....   | 5    |
| Table 3. Potential Contaminant Point Sources within the Bowie SWAA                |      |
| Water Quality Data .....  | 6    |
| Table 4. Summary of Water Quality Samples Bowie's Water Supply.                   |      |
| Susceptibility Analysis.....  | 8    |
| Table 5. Susceptibility Chart for Bowie's Water Supply                            |      |
| Management of the Wellhead Protection Area.....                                   | 10   |
| References.....   | 11   |
| Other Sources of Data.....  | 11   |
| Figures .....   | 12   |
| Figure 1. Bowie's Source Water Assessment Area with Potential Contaminant Sources |      |

## SUMMARY

The Maryland Department of the Environment's (MDE) Water Supply Program has conducted a Source Water Assessment for the City of Bowie. The major components of this report as described in Maryland's Source Water Assessment Plan (SWAP) are: 1) delineation of an area that contributes water to the source, 2) identification of potential sources of contamination, and 3) determination of the susceptibility of the water supply to contamination. Recommendations for management of the assessment area conclude this report.

The sources of the Bowie's water supply are three Coastal Plain confined aquifers—the Magothy, Patapsco and Patuxent. Six wells are currently being used to pump the water out of these aquifers. The source water assessment area was delineated by the Water Supply Program using methods approved by the U. S. EPA.

Potential sources of contamination within the assessment area were identified based on MDE site visits, a review of MDE's databases. Well information and water quality data were also reviewed. A map showing the source water assessment areas and potential contaminant sources is enclosed.

The susceptibility analysis for Bowie's water supply is based on a review of the water quality data, potential sources of contamination, aquifer characteristics, and well integrity. It was determined that Bowie's water supply is not susceptible to contaminants originating at the land surface due to the protected nature of confined aquifers. The water supply is susceptible to naturally occurring iron in the aquifers. The system has installed treatment to remove iron from the raw water.

## INTRODUCTION

The Maryland Department of the Environment's (MDE) Water Supply Program has conducted a Source Water Assessment for the City of Bowie. The City of Bowie is located approximately 15 miles northeast of Washington, D.C in Prince Georges County. The City owns and operates its water supply system that serves a population of 24,475. Currently, the water is being pumped from six wells (Nos. 1 – 6) and treated at a plant located at Bradford Lane. In 1992, the City of Bowie was awarded a Wellhead Protection Demonstration grant by the U.S. Environmental Agency (EPA), through which the City funded a Wellhead Protection Program study conducted by Horsley & Witten, Inc. The Horsley & Witten (1993) report was a major source of information for this assessment.

## WELL INFORMATION

Well information was obtained from the Water Supply Program's database, site visits, well completion reports, sanitary survey inspection reports and published reports. A review of the well data and sanitary surveys of the system indicates that four of the wells (Nos. 1, 2, 3 and 5) were drilled prior to 1973, when the State's well construction regulations went into effect, and may not meet current construction standards. Well Nos. 4R and 6 should meet construction standards for grouting and casing. Table 1 contains a summary of the well construction data. The database indicates that the City also has two wells for monitoring and two unused wells.

| SOURCE ID | SOURCE NAME             | PERMIT NO | TOTAL DEPTH (ft) | CASING DEPTH (ft) | YEAR DRILLED | AQUIFER NAME |
|-----------|-------------------------|-----------|------------------|-------------------|--------------|--------------|
| 01        | Bowie 1(A) Brierdale    | PG034997  | 192              | 110               | 1959         | MAGOTHY FM   |
| 02        | Bowie 2 (B) Brierdale   | PG034998  | 700              | 457               | 1959         | PATAPSCO FM  |
| 03        | Bowie 3 (D) Spangler Ln | PG043623  | 733              | 503               | 1961         | PATAPSCO FM  |
| 04        | Bowie 4R Plant          | PG880226  | 1158             | 1143              | 1989         | PATUXENT FM  |
| 05        | Bowie 5 (F)             | PG650085  | 980              | 905               | 1965         | PATUXENT FM  |
| 06        | Bowie 6                 | PG811879  | 715              | 425               | 1988         | PATAPSCO FM  |

Table 1. City of Bowie Well Information.

## HYDROGEOLOGY

Three Coastal Plain aquifers are used by the City of Bowie - the Magothy, Patapsco and Patuxent Formations. As can be seen from table 1, one well obtains water from the Magothy, three wells obtain water from the Patapsco and two wells from the Patuxent Formations. The Patapsco and Patuxent lie below the Magothy, with the Patuxent found directly above the crystalline bedrock which forms the base of the Coastal Plain aquifer system. These two formations are both part of the Potomac group and are

separated by a thick clay layer mapped as the Arundel Clay. A clay layer also separates the Magothy and Patapsco Formations.

In the Bowie area the Magothy, Patapsco and Patuxent aquifers are confined since they have overlying layers of clay and their outcrop areas are 1.5 miles (north and west of Well 1 A), 7.5 miles and 20 miles west of the City, respectively. The City may consider conducting further analysis or studies to confirm the confined nature of the Magothy aquifer. Ground water flow rates (in feet per day) were estimated for each aquifer for the wellhead protection study in 1993, and were as follows: Magothy: 0.61; Patapsco: 0.12; and Patuxent: 0.18. In the study, the age of the water was estimated by analyzing samples from each aquifer for tritium. The Magothy aquifer sample contained only trace concentrations of tritium suggesting a combination of older water mixing with newer water containing higher tritium concentrations. The samples from the Patapsco and Patuxent aquifers contain no tritium suggesting much older water. Based on the ground water flow rates, it takes approximately 900 years for the recharge water to flow to the Bowie wells in the Patapsco aquifer and approximately 1,600 years in the Patuxent aquifer.

## SOURCE WATER ASSESSMENT AREA DELINEATION

Source Water Assessment Areas (SWAAs) were delineated for the Bowie wells using the methodology described in Maryland's Source Water Assessment Plan (1999) for confined aquifers in the Coastal Plain, often referred to as the "Florida Method". The area is a radial zone of transport within the aquifer and is based on a 10 year time of travel (TOT), pumping rate and the screened interval(s) of the well or wells included in the SWAA, and the porosity of the aquifer (see illustration below for conceptual model). The Florida Method is a modification of Darcy's Law for radial flow to a well and the SWAA's were calculated using the following volumetric equation:


$$r = \sqrt{\frac{Qt}{\pi nH}}$$

where  $r$  = calculated fixed radius (ft)  
 $Q$  = pumping rate of well (ft<sup>3</sup>/yr)  
 $n$  = aquifer porosity (dimensionless)  
 $H$  = length of well screen (ft)  
 $t$  = time of travel (yr.)

Bowie has three water appropriation permits, one for each aquifer. Table 2 provides the values used and the calculated radius for each well. The pumping rate ( $Q$ ) used is the permitted daily average for the particular aquifer that the well is screened in. The total appropriated amount was used for each of the Patapsco and Patuxent aquifer wells, since most of the time the wells are rotated and pumped alternately.

A conservative estimate of porosity ( $n$ ) of 25% was used for each of the aquifers based on published reports. The lengths of the well screen ( $H$ ) were obtained from well

completion reports. In the instance that there were multiple screens, the sum of the individual screen lengths was used. Using these parameters the radius was calculated with the above equation for the SWAA delineation (Table 2). However for well 4R the screen length for well 5 of 75 feet was used rather than the very limited 10 feet screen length. The full saturated thickness of the aquifer is 87 feet. The circles for wells in the same aquifer were merged to form one larger SWAA. This resulted in one SWAA for each of the aquifers as shown in Figure 1. The circles represent the aquifer zone of transport in the subsurface as illustrated below.



*Conceptual illustration of a zone of transport for a confined aquifer*

| Well Name               | Well pumpage (Q) in gpd | Well pumpage (Q) in ft <sup>3</sup> /yr | Screened interval in feet | Aquifer      | Calculated radius for SWAA in feet | Acreage of WHPA | Comments on SWAA                |
|-------------------------|-------------------------|---|---------------------------|--------------|------------------------------------|-----------------|---------------------------------|
| BOWIE 1 (A) BRIERDALE   | 200000                  | 9758054                                 | 82                        | MAGOTHY FM   | 1300                               | 111             |                                 |
| BOWIE 2 (B) BRIERDALE   | 1500000                 | 73185403                                | 75                        | PATAPSCO FM  | 3600                               | 1624            | Wells 2, 3 and 6 circles merged |
| BOWIE 3 (D) SPANGLER LN | 1500000                 | 73185403                                | 96                        | PATAPSCO FM  | 3200                               |                 |                                 |
| BOWIE 6                 | 1500000                 | 73185403                                | 85                        | PATAPSCO FM  | 3400                               |                 |                                 |
| BOWIE 4R PLANT          | 1300000                 | 63427349                                | 75                        | PATUXENT FMN | 3300                               | 1324            | Wells 4R and 5 circles merged   |
| BOWIE 5 (F)             | 1300000                 | 63427349                                | 75                        | PATUXENT FM  | 3300                               |                 |                                 |

**Table 2. Parameters used for the Source Water Assessment Area delineations**

## POTENTIAL SOURCES OF CONTAMINATION

In confined aquifer settings, sources of contamination at the land surface are generally not a threat unless there is a pathway for direct injection into the deeper aquifer such as unused wells or along well casing that are not intact or have no grout seal. Wells that are not being maintained will eventually corrode and provide a pathway for contaminants present in the shallow aquifers at higher-pressure heads to migrate to the deeper aquifers.

Potential sources of contamination are classified as either point or non-point sources. Examples of point sources of contamination are leaking underground storage tanks, landfills, ground water discharge permits, large scale feeding operations and Superfund sites. These sites are generally associated with commercial or industrial facilities that use chemical substances that may, if inappropriately handled, contaminate ground water via discrete point location. Non-point sources of contamination are associated with certain types of land use practices such as the use of pesticides, application of fertilizers or animal wastes, or septic systems that may lead to ground water contamination over a larger area. All potential sources of contamination are identified at the land surface and therefore have the potential to impact the shallow water table aquifer. Therefore as long as there is no potential for direct injection into the deeper confined aquifers, Bowie's water supply should be well protected from ground water contamination. As indicated in the 1993 wellhead protection study for Bowie, the recharge area for the Magothy aquifer is within a fifty-year time of travel zone. The identification of potential sources of contamination in this area is beyond the scope of the State's source water assessment procedures. The reader is referred to the 1993 wellhead protection study for more information

Potential contaminant sources are identified if they fall within the SWAA for awareness and to ensure that the deep aquifers do not become affected by unused wells or poorly constructed wells in the water supply aquifers. Table 3 lists the facilities identified from MDE databases, as potential sources of contamination and their locations are shown in figure 1. Underground Storage Tanks (UST) sites are facilities that store petroleum or heating oil on site in underground tanks registered with the MDE Waste Management Administration. Controlled Hazardous Substance Generators (CHS) are facilities that may use or store any hazardous substance on site. The contaminants associated with the types of facilities are based on generalized categories and often the potential contaminant depends on the specific chemicals and processed being used at the individual facility. . The potential contaminants are not limited to those listed in table 4. Potential contaminants are grouped as Volatile Organic Compounds (VOC), Synthetic Organic Compounds (SOC) and Heavy Metals (HM).

| ID | Type    | Site Name                | Address            | Potential Contaminant | Status             |
|----|---------|--------------------------|--------------------|-----------------------|--------------------|
| 1  | UST     | Bowie High School        | 15200 Annapolis Rd | VOC                   | 1 tank, 1 removed  |
| 2  | UST     | Bowie Fire Dept. Co. #29 | 15454 Annapolis Rd | VOC                   | 2 tanks, 2 removed |
| 3  | CHS     | Diplomat Cleaners        | 15642 Annapolis Rd | VOC                   |                    |
| 4  | UST/CHS | Belair Amoco             | 15700 Annapolis Rd | VOC                   | 3 tanks, 6 removed |
| 5  | UST/CHS | Exxon # 25765            | 15711 Annapolis Rd | VOC                   | 5 tanks removed    |
| 6  | CHS     | Hilltop Cleaners         | 6822 Racetrack Rd  | VOC                   |                    |
| 7  | UST     | Nevey Shalom Synagogue   | 12215 Torah Ln     | VOC                   | 1 tank             |
| 8  | UST/CHS | Mobil Oil S/S 2634999    | 3233 Stonybrook Dr | VOC                   | 6 tanks, 4 removed |
| 9  | CHS     | Merchant's Tire & Auto   | 3298 Superior Ln   | VOC                   |                    |
| 10 | CHS     | Morning Sun Cleaners     | 3296 Superior Ln   | VOC                   |                    |
| 11 | CHS     | Bowie Internal Medicine  | 3231 Superior Ln   | VOC                   |                    |
| 12 | UST     | Wastewater Pump Stat #4  | 12626 Brunswick Ln | VOC                   | 1 tank             |
| 13 | UST     | Wastewater Pump Stat # 2 | 2200 Belair Rd     | VOC                   | 1 tank             |
| 14 | UST     | Bowie City Hall          | 2614 Kenhill Dr    | VOC                   | 1 tank             |

**Table 3. Potential Contaminant Point Sources within the Bowie SWAA (see figure 1 for locations).**

## WATER QUALITY DATA

Water Quality data was reviewed from the Water Supply Program's database and system files for Safe Drinking Water Act contaminants. The State's SWAP defines a threshold for reporting water quality data as 50% of the Maximum Contaminant Level (MCL). If a monitoring result is at or greater than 50% of a MCL, this assessment will describe the sources of such a contaminant and, if possible, locate the specific sources which are the cause of the elevated contaminant level. All data reported is from the finished (treated) water unless otherwise noted. The treatment currently used at Bowie is gaseous chlorination for disinfection, aeration, flocculation, sedimentation and filtration for iron removal, pH adjustment for corrosion control and addition of fluoride.

A review of the monitoring data since 1993 for Bowie's water supply indicates that it meets the current drinking water standards. The water quality sampling results are summarized in Table 3.

| IOCs                     |                          | SOCs                     |                          | VOCs                     |                          | Radionuclides            |                          |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| No. of Samples Collected | No. of samples > 50% MCL | No. of Samples Collected | No. of samples > 50% MCL | No. of Samples Collected | No. of samples > 50% MCL | No. of Samples Collected | No. of samples > 50% MCL |
| 15                       | 0                        | 5                        | 1*                       | 11                       | 0                        | 4                        | 0                        |

**Table 4. Summary of Water Quality Samples for Bowie's Water Supply**

\*found in blank

### ***Inorganic Compounds (IOCs)***

No IOCs above 50% of the MCL have been detected in Bowie's water supply since 1993. A review of the monthly operating reports, indicates that iron is present in the raw water at levels between 4 and 5 mg/l. Iron does not have an MCL but has a secondary standard based on taste and odor of 0.3 mg/l. The raw water that is being treated at Bowie's water plant is a combination from the Magothy, Patapsco and Patuxent aquifers. According to published reports the highest iron levels are in the Patapsco and lowest in the Magothy. Raw water quality data for Well 6 (Patapsco) shows iron levels at 10.8 mg/l.

### ***Volatile Organic Compounds (VOCs)***

No VOCs above 50% of the MCL have been detected in Bowie's water supply since 1993. The only VOCs that have been detected are very low levels of trihalomethanes (THMs). THMs are disinfection by-products formed as a result of the reaction between chlorine and dissolved organic compounds in the water supply. Low levels of THMS are typical for ground water systems.

### ***Synthetic Organic Compounds (SOCs)***

The only SOC detected above 50% of the MCL since 1993 was di (2-ethylhexyl) phthalate. Phthalate was detected at 4.5 ppb, in a sample collected on January 7, 2004. The MCL for phthlate is 6 ppb. Phthalate was found in laboratory blanks in samples collected on the same day and therefore this result does not represent the water quality. 2, 4-D was detected one time at 0.757 ppb in a sample collected on January 9, 2002. The MCL for dalapon is 70 ppb.

### ***Radionuclides***

No radionuclides above 50% of the MCL were detected in Bowie's water supply. Low levels of gross alpha, gross beta, radium and radon have been detected in the water supply.

### ***Microbiological Contaminants***

Routine bacteriological monitoring is conducted in the finished water for each community water system on a monthly basis and measures Total coliform bacteria. Since Bowie's water supply uses disinfection for its treatment, the finished water

data does not give much indication of the quality of raw water directly from the wells. Total coliform bacteria are not pathogenic, but are used as an indicator organism for other disease-causing microorganisms. A major breach of the system or the aquifers would likely cause a positive Total coliform result despite disinfection and would require follow-up total and fecal coliform analysis. Since 1994 Bowie has conducted routine bacteriological sampling 94 times, but no samples had any detections of total coliform bacteria.

## SUSCEPTIBILITY ANALYSIS

The wells serving Bowie's water supply pump water from three confined aquifers. Confined aquifers are naturally well protected from activity on the land surface due to low permeability sediments that provide a barrier for water movement from the surface into the aquifer below. A properly constructed well with the casing extended to the confining layer above the aquifer and with sufficient grout should be well protected from contamination at the land surface. Wells that are not being used or maintained will eventually corrode and provide a pathway for contaminants present in the shallow aquifers at higher-pressure heads to migrate to the deeper aquifers. The information that was used to conduct the susceptibility analysis is as follows: (1) available water quality data (2) presence of potential contaminant sources in the WHPA (3) aquifer characteristics (4) well integrity and (5) the likelihood of change to the natural conditions. The susceptibility of Bowie's water supply to the various contaminant groups is shown in table 4 at the end of this section.

### *Inorganic Compound (IOCs)*

No IOCs above 50% of the MCL have been detected in the Bowie water supply. Based on the natural occurrence of iron in the three aquifers supply Bowie, and high levels of iron in the raw water, Bowie's water supply is susceptible to iron.

Due to the naturally protected characteristics of the confined aquifers, the water quality data, and the lack of potential sources of contamination, Bowie's water supply **is not** susceptible to the other inorganic compounds.

### *Volatile Organic Compounds (VOCs)*

No VOCs above 50% of the MCL have been detected in Bowie's water supply.

Due to the naturally protected characteristics of the confined aquifers, the water quality data, and the lack of potential sources of contamination in the aquifers, Bowie's water supply **is not** susceptible to volatile organic compounds.

### *Synthetic Organic Compounds (SOCs)*

No SOCs above 50% of the MCL were detected in Bowie's water supply.

Due to the naturally protected characteristics of the confined aquifers, the water quality data, and the lack of potential sources of contamination, Bowie's water supply **is not** susceptible to synthetic organic compounds.

**Radionuclides**

No radionuclides above 50% of the MCL were detected in Bowie’s water supply. Only low levels of naturally occurring radium, radon, gross alpha and gross beta radiation have been detected in Bowie’s water supply.

Based on the water quality data, Bowie’s water supply is **not** susceptible to radiological contaminants.

**Microbiological Contaminants**

Raw water monitoring for microbiological contaminants is not required of water systems in confined aquifers because they are considered naturally protected from sources of pathogens at the land surface. Routine bacteriological testing for these plants revealed no positive Total Coliform in the water supply. Therefore, Bowie’s water supply is **not** susceptible to microbiological contaminants.

| CONTAMINANT TYPE                     | Are Contaminant Sources present in the WHPA? | Are Contaminants detected in WQ samples at 50% of the MCL | Is Well Integrity a Factor? | Is the Aquifer Vulnerable? | Is the System Susceptible to the Contaminant |
|--------------------------------------|--|---|-----------------------------|----------------------------|--|
| Iron                                 | YES*   | NO**  | NO                          | NO                         | YES  |
| Inorganic Compounds (except nitrate) | NO   | NO  | NO                          | NO                         | NO   |
| Volatile Organic Compounds           | NO   | NO  | NO                          | NO                         | NO   |
| Synthetic Organic Compounds          | NO   | NO  | NO                          | NO                         | NO   |
| Radionuclides                        | NO   | NO  | NO                          | NO                         | NO   |
| Microbiological Contaminants         | NO   | NO  | NO                          | NO                         | NO   |

**Table 5. Susceptibility Chart for Bowie’s Water Supply**

*\*Naturally occurring in the aquifer*

*\*\* Present in raw (untreated) water*

## MANAGEMENT OF THE WELLHEAD PROTECTION AREA

The City of Bowie took the initiative to promote Wellhead Protection in 1993, when they applied for and received a grant from the EPA to develop a Wellhead Protection Program. A Wellhead Protection Program report was completed by Horsley & Witten, Inc. in October 1993. The report provided a comprehensive section on water quality management strategies (Page 22). Also a *Summary of Wellhead Protection Tools* is shown in Table 7 of the Horsley & Witten report.

For the wellhead protection study the City selected 25 year TOT and 50 year TOT for delineating the wellhead protection areas. It is up to the City to decide which areas to use for wellhead protection implementation. The Source Water Assessment Areas were based on the criteria established by MDE in its EPA approved Source Water Assessment Plan (1999) for completion of the source water assessment for all public water systems. These areas can also be considered by the City as wellhead protection areas if so desired.

The Consumer Confidence Report should list that the Source Water Assessment has been completed and the report is available to the general public through the county public library or by contacting MDE.

## REFERENCES

- Horsley & Witten, Inc., 1993, Final Report Wellhead Protection Program, Bowie, Maryland, 30 p.
- Mack, Frederick, 1966, Ground water in Prince Georges County, Maryland, Department of Geology, Mines and Water Resources, Bulletin 29, 101p.
- Maryland Department of the Environment, Water Supply Program, 1999, Maryland's Source Water Assessment Plan, 36 p.
- Tompkins, Michael D, 1983, Prince George's County Ground-Water Information: Well records, chemical-quality data, pumpage, appropriation data, observation Well records, and well logs, Water Resources Basic Data Report No. 13, 160 p.
- United States Environmental Protection Agency, Office of Ground-Water Protection, 1987, Guidelines for Delineation of Wellhead Protection Areas.

## SOURCES OF DATA

Water Appropriation and Use Permit No. PG1961G008, PG1961G108, PG1961G208  
Public Water Supply Inspection Reports  
Monthly Operating Reports  
Monitoring Reports  
MDE Water Supply Program Oracle Database  
MDE Waste Management Sites Database  
Prince Georges digital ADC Map 2000